


SAFFTY CERTIFICATE

The School Building of Kutlehar Public School Balh Tehsil Bangana Distt Una (HP) has been inspected by the Junior Engineer concerned Section on dated 25.09.2019 As reported by Assistant Engineer Bangana Sub Division vide letter No PW/BSD/Building Safety/2019-20 - 4085 dated 28.09.2019, it has been observed that no earthquake resistant Provisions have been adopted for this building and no Structural drawings approved by the Competent Govt. Certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This Structure is a non-engineered Structure. Hence the Structural Safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building has been found safe at present only. No officer / official of this department will attend please in any Hon'ble Court of law in case of any dispute. This certificate is valid for the year 2020-21.


Executive Engineer
Bangana Divn.H.P.P.W.D.
BANGANA